SILVYN® LTPS-M

SILVYN® LTPS-M is a nickel-plated brass conduit fitting that offers a protection degree up to IP66/67/68/69



- Corrosion-resistant
- Maximum vibration protection
- Mechanical resistance
- Oil-resistant
- Optimum strain relief
- Robust

Benefits

High tensile strength
Vibration protection
High sealing performance

Application range

In combination with protective conduit:
SILVYN® LTP
Applications with high mechanical stress
Used in areas where liquids are present

Product Make-up

Metric connection thread
Hexagonal collar with torsion element

Last Update (22.02.2024)
©2024 Lapp Group - Technical changes reserved
Product Management www.lappkabel.de
You can find the current technical data in the corresponding data sheet.
PN 0456 / 02_03.16

SILVYN® LTPS-M

Threaded sleeve
Cap nut

Technical Data

Classification ETIM 5:	ETIM 5.0 Class-ID: EC001180 ETIM 5.0 Class-Description: Screw connection for protective metallic hose
Classification ETIM 6:	ETIM 6.0 Class-ID: EC001180 ETIM 6.0 Class-Description: Screw connection for protective metallic hose
Certifications:	IEC EN 61386-23
Material:	Body: nickel-plated brass Seal: PA compression seal
Protection rating:	IP66 IP67 IP68 (5 bar) IP69
Temperature range:	-50 °C to +135 °C

Note

Photographs and graphics are not to scale and do not represent detailed images of the respective products.
Prices are net prices without VAT and surcharges. Sale to business customers only.

©2024 Lapp Group - Technical changes reserved

LAPP

SILVYN® LTPS-M

PRODUCT INFORMATION

Article number	Metric size	SW wrench size mm	Thread length mm	Suitable for SILVYN® LTP	Pieces / PU
SILVYN® LTPS-M					
55510600	16 x 1.5/1	20.0	10	12	10
55510610	16 x 1.5/2	24.0	10	16	10
55510620	20 x 1.5/1	24.0	10	16	10
55510630	20 x 1.5/2	26.0	10	20	10
55510640	25 x 1.5	33.0	12	25	10
55510650	32 x 1.5	40.0	13	32	2

Last Update (22.02.2024)
©2024 Lapp Group - Technical changes reserved
Product Management www.lappkabel.de
You can find the current technical data in the corresponding data sheet.
PN 0456 / 02_03.16